TR 2021-09 – GM – Pressure Vessel Testing

Section 192.153

~~*This guide material is under review following Amendment 192-128.*~~

~~Section 192.153(e) requires that certain components, subject to the strength testing requirements of §192.505(b), be tested to at least 1.5 times the MAOP. It is the operator's responsibility to ensure that a component is tested in accordance with §192.153(e) by communicating design, specification, and testing requirements to the manufacturer or fabricator of the component. For pipelines operating below 30% SMYS, the operator might consider adopting specifications requiring strength testing of all components to at least 1.5 times the MAOP.~~

No guide material necessary.